PHOENIX
Environmental Laboratories, Inc.

**Monday, October 24, 2016**

**Mr. Joe Scollan**
**Bee & Jay Water Systems**
**P.O. Box 78 Route 6**
**Mahopac, NY 10541**

**Project ID: PUT VAL MIDDLE SCHOOL**
**Sample ID#s: BV52720 - BV52775, BV52777 - BV52789, BV52791 - BV52811**

**This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.**

**This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory.**

**A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.**

**If you have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext. 200.**

**Sincerely yours,**

**Phyllis Shiller**
**Laboratory Director**

**NELAC - #NY11301**
**CT Lab Registration #PH-0618**
**MA Lab Registration #MA-CT-007**
**ME Lab Registration #CT-007**
**NH Lab Registration #213693-A,B**
**NJ Lab Registration #CT-003**
**NY Lab Registration #11301**
**PA Lab Registration #68-03530**
**RI Lab Registration #63**
**VT Lab Registration #VT11301**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52720

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: 142 2

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0096 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/15/16 | AG/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52721

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: GIRLS BATH BY CAFE R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0092 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52722

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: GIRLS BATH BY CAFE L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0054 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52723

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: HANDICAP BATH R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0701 | 0.0020 | 4 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| ***** Lead exceeds Action Level of 0.015 ***** | | | | | | | | | | |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

## Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52724

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: BOYS BATH BY CAFE R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0116 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52725

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: BOYS BATH BY 205 L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0200 | 0.0020 | 4 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| ***** Lead exceeds Action Level of 0.015 ***** | | | | | | | | | | |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

## Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52726

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: BOYS BATH BY 202 L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0085 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52727

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: FACULTY MENS BY TECH

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0144 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52728

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: BOYS BATHROOM L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0839 | 0.0025 | 5 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| ***** Lead exceeds Action Level of 0.015 ***** | | | | | | | | | | |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

## Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52729

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: GIRL BATH BY TECH R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0065 | 0.0005 | 1 | mg/L | 0.015 | | | 10/20/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52730

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: FACULTY WOMENS BY TECH

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0082 | 0.0005 | 1 | mg/L | 0.015 | | | 10/20/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52731

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: KITCHEN 1

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0022 | 0.0005 | 1 | mg/L | 0.015 | | | 10/20/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52732

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: HALL SINK BY 212

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0046 | 0.0005 | 1 | mg/L | 0.015 | | | 10/20/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52733

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: WATER FOUNTAIN BY 208

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0065 | 0.0005 | 1 | mg/L | 0.015 | | | 10/20/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52734

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: 142 4

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0100 | 0.0020 | 4 | mg/L | 0.015 | | | 10/20/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52735

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: BOY BATH BY 205 R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0034 | 0.0005 | 1 | mg/L | 0.015 | | | 10/20/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52736

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: GIRLS ROOM BY 212 R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0026 | 0.0005 | 1 | mg/L | 0.015 | | | 10/20/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52737

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: GIRLS ROOM BY 208 L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0160 | 0.0020 | 4 | mg/L | 0.015 | | | 10/20/16 | RS | E200.9/SM3113B-10 |
| ***** Lead exceeds Action Level of 0.015 ***** | | | | | | | | | | |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

## Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52738

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: ART ROOM R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0057 | 0.0020 | 4 | mg/L | 0.015 | | | 10/20/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52739

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: FACULTY BATH EAST

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0135 | 0.0020 | 4 | mg/L | 0.015 | | | 10/20/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52740

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: BOYS ROOM BY 202 R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0084 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52741

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: ART ROOM L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0012 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52742

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: GIRLS ROOM BY 208 R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0076 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52743

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: WATER FOUNTAIN BY TECH

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0023 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52744

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: TEACHER ROOM SINK

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0127 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52745

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: ICE MACHINE

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0008 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52746

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: BOYS LOCKER ROOM

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0029 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52747

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: WATER FOUNTAIN CAFE

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0007 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52748

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: WATER FOUNTAIN BY ELEVATOR

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0016 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52749

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: MENS ROOM BY LOADING DOCK

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0033 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52750

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: KITCHEN 3

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0015 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52751

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: WOMENS ROOM BY LOADING DOCK

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0032 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52752

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: BOYS BATH BY CAFE L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0070 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52753

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: GIRLS ROOM 212 L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0088 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52754

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: SLOP SINK 2ND FLR

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0029 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52755

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: FACULTY MENS MAIN OFFICE

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0102 | 0.0020 | 4 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52756

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: BOYS BATH BY 205 M

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0108 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52757

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: SLOP SINK BY CAFE

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 1.37 | 0.100 | 4 | mg/L | 0.015 | | | 10/23/16 | RS | E200.9/SM3113B-10 |
| ***** Lead exceeds Action Level of 0.015 ***** | | | | | | | | | | |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

## Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52758

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: KITCHEN 4

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0222 | 0.0020 | 4 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| ***** Lead exceeds Action Level of 0.015 ***** | | | | | | | | | | |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

## Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52759

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: SLOP SINK BY 142

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0026 | 0.0020 | 4 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52760

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: HALL SINK 202

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0126 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52761

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: GIRLS LOCKER ROOM

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0094 | 0.0020 | 4 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52762

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: KITCHEN 2

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0037 | 0.0005 | 1 | mg/L | 0.015 | | | 10/21/16 | RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52763

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: FACULTY WOMEN BY MAIN OFFICE

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0154 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| ***** Lead exceeds Action Level of 0.015 ***** | | | | | | | | | | |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

## Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52764

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: 142 2

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0055 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52765

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: GIRLS ROOM BY 212 M

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0064 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52766

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: BAND ROOM

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.252 | 0.0050 | 10 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| ***** Lead exceeds Action Level of 0.015 ***** | | | | | | | | | | |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

## Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52767

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: CUSTODIAN OFFICE

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0047 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52768

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: FACULTY BATH WEST

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0084 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52769

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: BOYS ROOM BY 202 M

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0052 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52770

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: HANDICAP BATH L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0606 | 0.0020 | 4 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| ***** Lead exceeds Action Level of 0.015 ***** | | | | | | | | | | |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

## Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52771

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: NURSES BACKROOM

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0151 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| ***** Lead exceeds Action Level of 0.015 ***** | | | | | | | | | | |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

## Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52772

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: WATER FOUNTAIN BY MAIN OFFICE

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0021 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52773

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: NURSES BATHROOM

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0046 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52774

Project ID: PUT VAL MIDDLE SCHOOL
Client ID: LIBRARY

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0068 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52775

Project ID: PUT VAL HIGH SCHOOL
Client ID: 1ST FLR WATER FOUNTAIN L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | < 0.0005 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52777

Project ID: PUT VAL HIGH SCHOOL
Client ID: 1ST FLR BOYS ROOM FISHBOWL L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0009 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52778

Project ID: PUT VAL HIGH SCHOOL
Client ID: 1ST FLR GIRLS ROOM FISHBOWL R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0006 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52779

Project ID: PUT VAL HIGH SCHOOL
Client ID: 1ST FLR FISHBOWL SLOP SINK

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0023 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52780

Project ID: PUT VAL HIGH SCHOOL
Client ID: ROOM 109 L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | < 0.0005 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52781

Project ID: PUT VAL HIGH SCHOOL
Client ID: ROOM 109 R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0006 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52782

Project ID: PUT VAL HIGH SCHOOL
Client ID: BOYS ROOM GYM R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0008 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52783

Project ID: PUT VAL HIGH SCHOOL
Client ID: 1ST FLOOR FISH BOWL FACULTY GIRLS

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | < 0.0005 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52784

Project ID: PUT VAL HIGH SCHOOL
Client ID: 1ST FLOOR FISH BOWL BOYS R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0007 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52785

Project ID: PUT VAL HIGH SCHOOL
Client ID: 1ST FLOOR FISH BOWL GIRLS L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0011 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52786

Project ID: PUT VAL HIGH SCHOOL
Client ID: BOYS LOCKER ROOM L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0008 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52787

Project ID: PUT VAL HIGH SCHOOL
Client ID: 118 TEACHER ROOM

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0030 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52788

Project ID: PUT VAL HIGH SCHOOL
Client ID: 122 R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | < 0.0005 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/G | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52789

Project ID: PUT VAL HIGH SCHOOL
Client ID: GIRLS ROOM GYM R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0007 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52791

Project ID: PUT VAL HIGH SCHOOL
Client ID: 1ST FLOOR FISH BOWL FACULTY MENS

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0006 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52792

Project ID: PUT VAL HIGH SCHOOL
Client ID: 1ST FLOOR FISH BOWL GIRLS M

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0009 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.



**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52793

Project ID: PUT VAL HIGH SCHOOL
Client ID: TEAM LOCKER ROOM

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | < 0.0005 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52794

Project ID: PUT VAL HIGH SCHOOL
Client ID: BOYS LOCKER ROOM R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0006 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52795

Project ID: PUT VAL HIGH SCHOOL
Client ID: 1ST FLR FISHBOWL FOUNTAIN R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | < 0.0005 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52796

Project ID: PUT VAL HIGH SCHOOL
Client ID: ICE MACHINE

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0007 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52797

Project ID: PUT VAL HIGH SCHOOL
Client ID: 113 R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0020 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52798

Project ID: PUT VAL HIGH SCHOOL
Client ID: DARK ROOM

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | < 0.0005 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52799

Project ID: PUT VAL HIGH SCHOOL
Client ID: SLOP SINK BY GYM

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0012 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52800

Project ID: PUT VAL HIGH SCHOOL
Client ID: GIRLS LOCKER ROOM R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | < 0.0005 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52801

Project ID: PUT VAL HIGH SCHOOL
Client ID: 122 L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | < 0.0005 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52802

Project ID: PUT VAL HIGH SCHOOL
Client ID: 1ST FLR FISH BOWL BOYS ROOM N7

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0006 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52803

Project ID: PUT VAL HIGH SCHOOL
Client ID: 113 L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0011 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52804

Project ID: PUT VAL HIGH SCHOOL
Client ID: GIRLS LOCKER ROOM L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0006 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52805

Project ID: PUT VAL CONCESSION STAND
Client ID: KITCHEN SINK

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0039 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52806

Project ID: PUT VAL CONCESSION STAND
Client ID: WATER FOUNTAIN L

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | < 0.0005 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52807

Project ID: PUT VAL CONCESSION STAND
Client ID: LADIES ROOM

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0006 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52808

Project ID: PUT VAL CONCESSION STAND
Client ID: ICE MACHINE

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0011 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/16/16 | G/E/AG | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52809

Project ID: PUT VAL CONCESSION STAND
Client ID: SPIGOT BY FOUNTAIN

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0006 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/18/16 | /BF | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52810

Project ID: PUT VAL CONCESSION STAND
Client ID: WATER FOUNTAIN R

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | < 0.0005 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/18/16 | /BF | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# Analysis Report

October 24, 2016

FOR: Mr. Joe Scollan
Bee & Jay Water Systems
P.O. Box 78 Route 6
Mahopac, NY 10541

| Sample Information | | Custody Information | | Date | Time |
|---|---|---|---|---|---|
| Matrix: | DRINKING WATER | Collected by: | | 10/14/16 | |
| Location Code: | BEEJAYPVS | Received by: | SW | 10/14/16 | 17:02 |
| Rush Request: | Standard | Analyzed by: | see "By" below | | |
| P.O.#: | | | | | |

## Laboratory Data

SDG ID: GBV52720
Phoenix ID: BV52811

Project ID: PUT VAL CONCESSION STAND
Client ID: MENS ROOM

| Parameter | Result | RL/ PQL | DIL | Units | AL | MCL | MCLG | Date/Time | By | Reference |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 0.0016 | 0.0005 | 1 | mg/L | 0.015 | | | 10/22/16 | MA/RS | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed | | | | | | | 10/18/16 | /BF | E200.9 |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**
**October 24, 2016**
**Reviewed and Released by: Deb Lawrie, Project Manager**

Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

NY # 11301

# QA/QC Report

October 24, 2016

## QA/QC Data

SDG I.D.: GBV52720

| Parameter | Blank | Blk RL | Sample Result | Dup Result | Dup RPD | LCS % | LCSD % | LCS RPD | MS % | MSD % | MS RPD | % Rec Limits | % RPD Limits | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| QA/QC Batch 363012 (mg/L), QC Sample No: BV47934 (BV52721) | | | | | | | | | | | | | | |
| Lead | BRL | 0.001 | 0.0052 | 0.005 | 3.90 | 94.7 | | | 96.0 | | | 85 - 115 | 20 | |
| Comment: | | | | | | | | | | | | | | |
| Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%. | | | | | | | | | | | | | | |
| QA/QC Batch 363012A (mg/L), QC Sample No: BV47944 (BV52720) | | | | | | | | | | | | | | |
| Lead | BRL | 0.001 | | | | 94.7 | | | 73.0 | | | 85 - 115 | 20 | m |
| Comment: | | | | | | | | | | | | | | |
| This batch does not include a duplicate. | | | | | | | | | | | | | | |
| Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%. | | | | | | | | | | | | | | |
| QA/QC Batch 363039A (mg/L), QC Sample No: BV50679 (BV52721, BV52722, BV52723, BV52724, BV52725, BV52726, BV52727, BV52728) | | | | | | | | | | | | | | |
| Lead | BRL | 0.001 | | | | 100 | | | 97.1 | | | 85 - 115 | 20 | |
| Comment: | | | | | | | | | | | | | | |
| This batch does not include a duplicate. | | | | | | | | | | | | | | |
| Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%. | | | | | | | | | | | | | | |
| QA/QC Batch 363040 (mg/L), QC Sample No: BV52729 (BV52729, BV52730, BV52731, BV52732, BV52733, BV52734, BV52735, BV52736, BV52737, BV52738) | | | | | | | | | | | | | | |
| Lead | BRL | 0.001 | 0.0065 | 0.007 | 7.40 | 88.4 | | | 87.2 | | | 85 - 115 | 20 | |
| Comment: | | | | | | | | | | | | | | |
| Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%. | | | | | | | | | | | | | | |
| QA/QC Batch 363040A (mg/L), QC Sample No: BV52739 (BV52739, BV52740, BV52741, BV52742, BV52743, BV52744, BV52745, BV52746, BV52747, BV52748) | | | | | | | | | | | | | | |
| Lead | BRL | 0.001 | | | | 88.4 | | | 82.5 | | | 85 - 115 | 20 | |
| Comment: | | | | | | | | | | | | | | |
| This batch does not include a duplicate. | | | | | | | | | | | | | | |
| Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%. | | | | | | | | | | | | | | |
| QA/QC Batch 363041 (mg/L), QC Sample No: BV52749 (BV52749, BV52750, BV52751, BV52752, BV52753, BV52754, BV52755, BV52756, BV52757, BV52758) | | | | | | | | | | | | | | |
| Lead | BRL | 0.001 | 0.0033 | 0.003 | NC | 88.8 | | | 89.3 | | | 85 - 115 | 20 | |
| Comment: | | | | | | | | | | | | | | |
| Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%. | | | | | | | | | | | | | | |
| QA/QC Batch 363041A (mg/L), QC Sample No: BV52759 (BV52759, BV52760, BV52761, BV52762, BV52763, BV52764, BV52765, BV52766, BV52767, BV52768) | | | | | | | | | | | | | | |
| Lead | BRL | 0.001 | | | | 88.8 | | | 89.0 | | | 85 - 115 | 20 | |
| Comment: | | | | | | | | | | | | | | |
| This batch does not include a duplicate. | | | | | | | | | | | | | | |
| Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%. | | | | | | | | | | | | | | |
| QA/QC Batch 363042 (mg/L), QC Sample No: BV52769 (BV52769, BV52770, BV52771, BV52772, BV52773, BV52774, BV52775, BV52777, BV52778) | | | | | | | | | | | | | | |
| Lead | BRL | 0.001 | 0.0052 | 0.005 | 3.90 | 95.5 | | | 87.4 | | | 85 - 115 | 20 | |

# QA/QC Data

SDG I.D.: GBV52720

| Parameter | Blank | Blk RL | Sample Result | Dup Result | Dup RPD | LCS % | LCSD % | LCS RPD | MS % | MSD % | MS RPD | % Rec Limits | % RPD Limits |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Comment: | | | | | | | | | | | | | |
| Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%. | | | | | | | | | | | | | |
| QA/QC Batch 363042A (mg/L), QC Sample No: BV52779 (BV52779, BV52780, BV52781, BV52782, BV52783, BV52784, BV52785, BV52786, BV52787, BV52788) | | | | | | | | | | | | | |
| Lead | BRL | 0.001 | | | | 95.5 | | | 83.0 | | | 85 - 115 | 20 |
| Comment: | | | | | | | | | | | | | |
| This batch does not include a duplicate. | | | | | | | | | | | | | |
| Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%. | | | | | | | | | | | | | |
| QA/QC Batch 363043 (mg/L), QC Sample No: BV52789 (BV52789, BV52791, BV52792, BV52793, BV52794, BV52795, BV52796, BV52797, BV52798) | | | | | | | | | | | | | |
| Lead | BRL | 0.001 | 0.0007 | 0.001 | NC | 95.5 | | | 90.3 | | | 85 - 115 | 20 |
| Comment: | | | | | | | | | | | | | |
| Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%. | | | | | | | | | | | | | |
| QA/QC Batch 363043A (mg/L), QC Sample No: BV52799 (BV52799, BV52800, BV52801, BV52802, BV52803, BV52804, BV52805, BV52806, BV52807, BV52808) | | | | | | | | | | | | | |
| Lead | BRL | 0.001 | | | | 95.5 | | | 82.3 | | | 85 - 115 | 20 |
| Comment: | | | | | | | | | | | | | |
| This batch does not include a duplicate. | | | | | | | | | | | | | |
| Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%. | | | | | | | | | | | | | |

m = This parameter is outside laboratory MS/MSD specified recovery limits.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

RPD - Relative Percent Difference
LCS - Laboratory Control Sample
LCSD - Laboratory Control Sample Duplicate
MS - Matrix Spike
MS Dup - Matrix Spike Duplicate
NC - No Criteria
Intf - Interference

Phyllis Shiller, Laboratory Director
October 24, 2016

# Sample Criteria Exceedances Report

## GBV52720 - BEEJAYPVS



Criteria: None

State: NY

| SampNo | Acode | Phoenix Analyte | Criteria | Result | RL | Criteria | RL Criteria | Analysis Units |
|---|---|---|---|---|---|---|---|---|
| BV52723 | PB-DW | Lead | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.0701 | 0.0020 | 0.015 | 0.001 | mg/L |
| BV52723 | PB-DW | Lead | NY / NY Residential DW / Lead & Copper Als | 0.0701 | 0.0020 | 0.015 | 0.015 | mg/L |
| BV52725 | PB-DW | Lead | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.0200 | 0.0020 | 0.015 | 0.001 | mg/L |
| BV52725 | PB-DW | Lead | NY / NY Residential DW / Lead & Copper Als | 0.0200 | 0.0020 | 0.015 | 0.015 | mg/L |
| BV52728 | PB-DW | Lead | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.0839 | 0.0025 | 0.015 | 0.001 | mg/L |
| BV52728 | PB-DW | Lead | NY / NY Residential DW / Lead & Copper Als | 0.0839 | 0.0025 | 0.015 | 0.015 | mg/L |
| BV52737 | PB-DW | Lead | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.0160 | 0.0020 | 0.015 | 0.001 | mg/L |
| BV52737 | PB-DW | Lead | NY / NY Residential DW / Lead & Copper Als | 0.0160 | 0.0020 | 0.015 | 0.015 | mg/L |
| BV52757 | PB-DW | Lead | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 1.37 | 0.100 | 0.015 | 0.001 | mg/L |
| BV52757 | PB-DW | Lead | NY / NY Residential DW / Lead & Copper Als | 1.37 | 0.100 | 0.015 | 0.015 | mg/L |
| BV52758 | PB-DW | Lead | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.0222 | 0.0020 | 0.015 | 0.001 | mg/L |
| BV52758 | PB-DW | Lead | NY / NY Residential DW / Lead & Copper Als | 0.0222 | 0.0020 | 0.015 | 0.015 | mg/L |
| BV52763 | PB-DW | Lead | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.0154 | 0.0005 | 0.015 | 0.001 | mg/L |
| BV52763 | PB-DW | Lead | NY / NY Residential DW / Lead & Copper Als | 0.0154 | 0.0005 | 0.015 | 0.015 | mg/L |
| BV52766 | PB-DW | Lead | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.252 | 0.0050 | 0.015 | 0.001 | mg/L |
| BV52766 | PB-DW | Lead | NY / NY Residential DW / Lead & Copper Als | 0.252 | 0.0050 | 0.015 | 0.015 | mg/L |
| BV52770 | PB-DW | Lead | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.0606 | 0.0020 | 0.015 | 0.001 | mg/L |
| BV52770 | PB-DW | Lead | NY / NY Residential DW / Lead & Copper Als | 0.0606 | 0.0020 | 0.015 | 0.015 | mg/L |
| BV52771 | PB-DW | Lead | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.0151 | 0.0005 | 0.015 | 0.001 | mg/L |
| BV52771 | PB-DW | Lead | NY / NY Residential DW / Lead & Copper Als | 0.0151 | 0.0005 | 0.015 | 0.015 | mg/L |

Phoenix Laboratories does not assume responsibility for the data contained in this report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.

**Environmental Laboratories, Inc.**
**587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045**
**Tel. (860) 645-1102 Fax (860) 645-0823**

ACCREDITED IN ACCORDANCE WITH nelac NY # 11301

# NY Temperature Narration

**October 24, 2016**

**SDG I.D.: GBV52720**

The samples in this delivery group were received at 22°C.
(Note acceptance criteria is above freezing up to 6°C)

# PHOENIX Environmental Laboratories, Inc.

## NY/NJ CHAIN OF CUSTODY RECORD

Temp 22.4°C Pg 1 of 9

587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06040
Email: info@phoenixlabs.com Fax (860) 645-0823
**Client Services (860) 645-8726**

**Data Delivery:**
☐ Fax #:
☒ Email: joe@beeandjayplumbing.com

Customer: Bee & Jay Water Systems
Address: P.O. Box 78, Route 6
Mahopac, NY 10541

Project: PUT VDL MIDDLE SCHOOL
Report to: Joseph Scollan
Invoice to:

Project P.O:
Phone #: 845-628-3924
Fax #: 845-628-4062

**Client Sample - Information - Identification**

Sampler's Signature: Jimmy Weeks Date: 10/14/16

**Matrix Code:**
DW=drinking water WW=wastewater S=soil/solid O=oil
GW=groundwater SL=sludge A=air X=other

Analysis Request

| Phoenix Sample # | Customer Sample Identification | Sample Matrix | Date Sampled | Time Sampled | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | Soil VOA [ ] Methanol [ ] S. Bisulfate [ ] H2O | GL Soil container ( ) oz | GL Soil container ( ) oz | 40 ml VOA Vial [ ] As is [ ] HCl | GL Amber 1000ml [ ] As is [ ] H2SO4 | PL As is [ ] 250ml [ ] 500ml [ ] 1000ml | PL H2SO4 [ ] 250ml [ ] 500ml | PL HNO3 250ml | PL NaOH 250ml | Bacteria Bottle |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| S2720 | 142 2 | | | | X | | | | | | | | | | | | | | | | | | | | |
| S2721 | GIRLS BATH BY CAFE | R | | | | X | | | | | | | | | | | | | | | | | | | |
| S2722 | GIRLS BATH BY CAFE | L | | | | | X | | | | | | | | | | | | | | | | | | |
| S2723 | HANDICAP BATH R | | | | | | | X | | | | | | | | | | | | | | | | | |
| S2724 | BOYS BATH BY CAFE R | | | 1ST | | | | | X | | | | | | | | | | | | | | | | |
| S2725 | BOYS BATH BY 205 L | | 10/14 | DRAW | | | | | | X | | | | | | | | | | | | | | | |
| S2726 | BOYS ROOM BY 202 L | | | | | | | | | | X | | | | | | | | | | | | | | |
| S2727 | FACULTY MENS BY TECH | DW | | | | | | | | | | X | | | | | | | | | | | | | |
| S2728 | BOYS BATHROOM L | | | | | | | | | | | | X | | | | | | | | | | | | |
| S2729 | GIRL BATH BY TECH R | | | | | | | | | | | | | X | | | | | | | | | | | |
| S2730 | FACULTY WOMENS BY TECH | | | | | | | | | | | | | | X | | | | | | | | | | |
| S2731 | KITCHEN 1 | | | | | | | | | | | | | | | X | | | | | | | | | |

| Relinquished by: | Accepted by: | Date: | Time: |
|---|---|---|---|
| | | 10/14/16 | 1245 |
| | | 10/14/16 | 3pm |
| | | 10/14/16 | 17:02 |

**Comments, Special Requirements or Regulations:**

Putnam Valley School District
173 Oscawana Lake Road
Putnam Valley, NY 10579

**Turnaround:**
☐ 1 Day*
☐ 2 Days*
☐ 3 Days* Day*
☐ 5 Days
☐ 10 Days
☐ Other
* SURCHARGE APPLIES

**NJ**
☐ Res. Criteria
☐ Non-Res. Criteria
☐ Impact to GW Soil Cleanup Criteria
☐ GW Criteria

**NY**
☐ TAGM 4046 GW
☐ TAGM 4046 SOIL
☐ NY375 Unrestricted Soil
☐ NY375 Residential Soil
☐ NY375 Restricted Non-Residential Soil

**Data Format**
☐ Phoenix Std Report
☐ Excel
☐ PDF
☐ GIS/Key
☐ EQuIS
☐ NJ Hazsite EDD
☐ NY EZ EDD (ASP)
☐ Other

**Data Package**
☐ NJ Reduced Deliv. *
☐ NY Enhanced (ASP B) *
☐ Other

**State where samples were collected:** NY

# PHOENIX Environmental Laboratories, Inc.

## NY/NJ CHAIN OF CUSTODY RECORD

Temp 32°F Pg 2 of 4

587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06040
Email: info@phoenixlabs.com Fax (860) 645-0823
**Client Services (860) 645-8726**

**Data Delivery:**
☐ Fax #:
☒ Email: joe@beeandjayplumbing.com

Customer: Bee & Jay Water Systems
Address: P.O. Box 78, Route 6
Mahopac, NY 10541

Project: PUTNAM VALLEY MIDDLE SCHOOL
Report to: Joseph Scollan
Invoice to:

Project P.O:
Phone #: 845-628-3924
Fax #: 845-628-4062

**Client Sample - Information - Identification**

Sampler's Signature: Henry Wiehn Date: 10/14/16

**Matrix Code:**
DW=drinking water WW=wastewater S=soil/solid O=oil
GW=groundwater SL=sludge A=air X=other

Analysis Request

| Phoenix Sample # | Customer Sample Identification | Sample Matrix | Date Sampled | Time Sampled | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | Soil VOA [ ] Methanol [ ] S. Bisulfate [ ] H2O | GL Soil container ( ) oz | GL Soil container ( ) oz | 40 ml VOA Vial [ ] As is [ ] HCl | GL Amber 1000ml [ ] As is [ ] H2SO4 | PL As is [ ] 250ml [ ] 500ml [ ] 1000ml | PL H2SO4 [ ] 250ml [ ] 500ml | PL HNO3 250ml | PL NaOH 250ml | Bacteria Bottle |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 52732 | HALL SINK BY 212 R | DW | 10/14 | 1ST DRAW | X | | | | | | | | | | | | | | | | | | | |
| 52733 | WATER FOUNTAIN BY 208 | | | | | X | | | | | | | | | | | | | | | | | | |
| 52734 | 142 H | | | | | | X | | | | | | | | | | | | | | | | | |
| 52735 | BOY BATH BY 205 R | | | | | | | X | | | | | | | | | | | | | | | | |
| 52736 | GIRLS ROOM BY 210 R | | | | | | | | X | | | | | | | | | | | | | | | |
| 52737 | GIRLS ROOM BY 208 L | | | | | | | | | X | | | | | | | | | | | | | | |
| 52738 | ART ROOM R | | | | | | | | | | X | | | | | | | | | | | | | |
| 52739 | FACULTY BATH EAST | | | | | | | | | | | X | | | | | | | | | | | | |
| 52740 | BOYS ROOM BY 202 R | | | | | | | | | | | | X | | | | | | | | | | | |
| 52741 | ART ROOM L | | | | | | | | | | | | | X | | | | | | | | | | |
| 52742 | GIRLS ROOM BY 208 R | | | | | | | | | | | | | | X | | | | | | | | | |
| 52743 | WATER FOUNTAIN BY TECH | | | | | | | | | | | | | | | X | | | | | | | | |

| Relinquished by: | Accepted by: | Date: | Time: |
|---|---|---|---|
| KP | | 10/14/16 | 1245 |
| | | 10/14/16 | 300 |
| | | 10/14/16 | 17:02 |

**Comments, Special Requirements or Regulations:**

Putnam Valley School District
173 Oscawana Lake Road
Putnam Valley, NY 10579

**Turnaround:**
☐ 1 Day*
☐ 2 Days*
☐ 3 Days* Day*
☐ 5 Days
☐ 10 Days
☐ Other
* SURCHARGE APPLIES

**NJ**
☐ Res. Criteria
☐ Non-Res. Criteria
☐ Impact to GW Soil Cleanup Criteria
☐ GW Criteria

**NY**
☐ TAGM 4046 GW
☐ TAGM 4046 SOIL
☐ NY375 Unrestricted Soil
☐ NY375 Residential Soil
☐ NY375 Restricted Non-Residential Soil

**Data Format**
☐ Phoenix Std Report
☐ Excel
☐ PDF
☐ GIS/Key
☐ EQuIS
☐ NJ Hazsite EDD
☐ NY EZ EDD (ASP)
☐ Other

**Data Package**
☐ NJ Reduced Deliv. *
☐ NY Enhanced (ASP B) *
☐ Other

**State where samples were collected:** NY

# NY/NJ CHAIN OF CUSTODY RECORD

Temp 22 on ice — Pg 3 of 9

**PHOENIX** *Environmental Laboratories, Inc.*

587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06040
Email: info@phoenixlabs.com Fax (860) 645-0823
**Client Services (860) 645-8726**

**Data Delivery:**
☐ Fax #:
☒ Email: joe@beeandjayplumbing.com

Customer: Bee & Jay Water Systems
Address: P.O. Box 78, Route 6
Mahopac, NY 10541

Project: PUT VAL MIDDLE SCHOOL
Report to: Joseph Scollan
Invoice to:

Project P.O:
Phone #: 845-628-3924
Fax #: 845-628-4062

Client Sample - Information - Identification

Sampler's Signature: Jeremy Cole Date: 10/14/16

**Matrix Code:**
DW=drinking water WW=wastewater S=soil/solid O=oil
GW=groundwater SL=sludge A=air X=other

Analysis Request

| Phoenix Sample # | Customer Sample Identification | Sample Matrix | Date Sampled | Time Sampled | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | Soil VOA [ ] Methanol [ ] S. Bisulfate [ ] H2O | GL Soil container ( ) oz | GL Soil container ( ) oz | 40 ml VOA Vial [ ] As is [ ] HCl | GL Amber 1000ml [ ] As is [ ] H2SO4 | PL As is [ ] 250ml [ ] 500ml [ ] 1000ml | PL H2SO4 [ ] 250ml [ ] 500ml [ ] 1000ml | PL HNO3 250ml | PL NaOH 250ml | Bacteria Bottle |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 52744 | TEACHER ROOM SINK | | | | X | | | | | | | | | | | | | | | | | | | |
| 52745 | ICE MACHINE | | | | | X | | | | | | | | | | | | | | | | | | |
| 52746 | BOYS LOCKER ROOM | | | | | | X | | | | | | | | | | | | | | | | | |
| 52747 | WATER FOUNTAIN CAFE | | | | | | | X | | | | | | | | | | | | | | | | |
| 52748 | WATER FOUNTAIN BY ELEVATOR | DW | 10/14 | | | | | | X | | | | | | | | | | | | | | | |
| 52749 | MENS ROOM BY LOADING DOCK | | | BT | | | | | | X | | | | | | | | | | | | | | |
| 52750 | KITCHEN 3 | | | DRAW | | | | | | | X | | | | | | | | | | | | | |
| 52751 | WOMENS ROOM BY LOADING DOCK | | | | | | | | | | | X | | | | | | | | | | | | |
| 52752 | BOYS BATH BY CAFE | | | | | | | | | | | | X | | | | | | | | | | | |
| 52753 | GIRLS ROOM 2ND FL | | | | | | | | | | | | | X | | | | | | | | | | |
| 52754 | SLOP SINK 2ND FLOOR | | | | | | | | | | | | | | X | | | | | | | | | |
| 52755 | FACULTY MENS MAIN OFFICE | | | | | | | | | | | | | | | X | | | | | | | | |

| Relinquished by: | Accepted by: | Date: | Time: |
|---|---|---|---|
| | | 10/14/16 | 1245 |
| | | 10/14/16 | 300 |
| | | 10/14/16 | 17:00 |

Comments, Special Requirements or Regul

Putnam Valley School District
173 Oscawana Lake Road
Putnam Valley, NY 10579

**Turnaround:**
☐ 1 Day*
☐ 2 Days*
☐ 3 Days* Day*
☐ 5 Days
☐ 10 Days
☐ Other
* SURCHARGE APPLIES

**NJ**
☐ Res. Criteria
☐ Non-Res. Criteria
☐ Impact to GW Soil Cleanup Criteria
☐ GW Criteria

**NY**
☐ TAGM 4046 GW
☐ TAGM 4046 SOIL
☐ NY375 Unrestricted Soil
☐ NY375 Residential Soil
☐ NY375 Restricted Non-Residential Soil

**Data Format**
☐ Phoenix Std Report
☐ Excel
☐ PDF
☐ GIS/Key
☐ EQuIS
☐ NJ Hazsite EDD
☐ NY EZ EDD (ASP)
☐ Other

**Data Package**
☐ NJ Reduced Deliv. *
☐ NY Enhanced (ASP B) *
☐ Other

**State where samples were collected:** NY

# PHOENIX Environmental Laboratories, Inc.

## NY/NJ CHAIN OF CUSTODY RECORD

Temp 22ONIC Pg 4 of 9

587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06040
Email: info@phoenixlabs.com Fax (860) 645-0823
**Client Services (860) 645-8726**

**Data Delivery:**
☐ Fax #:
☒ Email: joe@beeandjayplumbing.com

Customer: Bee & Jay Water Systems
Address: P.O. Box 78, Route 6
Mahopac, NY 10541

Project: PUTNAM MIDDLE SCHOOL
Report to: Joseph Scollan
Invoice to:

Project P.O:
Phone #: 845-628-3924
Fax #: 845-628-4062

Sampler's Signature: Henry Weber Date: 10/14/16

**Client Sample - Information - Identification**

**Matrix Code:**
**DW**=drinking water **WW**=wastewater **S**=soil/solid **O**=oil
**GW**=groundwater **SL**=sludge **A**=air **X**=other

Analysis Request

| Phoenix Sample # | Customer Sample Identification | Sample Matrix | Date Sampled | Time Sampled | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | Soil VOA [ ] Methanol [ ] S. Bisulfate [ ] H2O | GL Soil container ( ) oz | GL Soil container ( ) oz | 40 ml VOA Vial [ ] As is [ ] HCl | GL Amber 1000ml [ ] As is [ ] H2SO4 | PL As is [ ] 250ml [ ] 500ml [ ] 1000ml | PL H2SO4 [ ] 250ml [ ] 500ml | PL HNO3 250ml | PL NaOH 250ml | Bacteria Bottle |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 52756 | BOYS BATH 84 LOS M | DW | 10/14 | 1st DRAW | X | | | | | | | | | | | | | | | | | | | |
| 52757 | SLOP SINK BY CAFE | | | | | X | | | | | | | | | | | | | | | | | | |
| 52758 | KITCHEN 4 | | | | | | X | | | | | | | | | | | | | | | | | |
| 52759 | SLOP SINK BY 142 | | | | | | | X | | | | | | | | | | | | | | | | |
| 52760 | HALL SINK 202 | | | | | | | | X | | | | | | | | | | | | | | | |
| 52761 | GIRLS LOCKER ROOM DW | | | | | | | | | X | | | | | | | | | | | | | | |
| 52762 | KITCHEN 2 | | | | | | | | | | X | | | | | | | | | | | | | |
| 52763 | FACULTY WOMEN BY MAINS OFFICE | | | | | | | | | | | X | | | | | | | | | | | | |
| 52764 | 142 1 | | | | | | | | | | | | X | | | | | | | | | | | |
| 52765 | GIRLS Room BY 202 M | | | | | | | | | | | | | X | | | | | | | | | | |
| 52766 | BAND ROOM | | | | | | | | | | | | | | X | | | | | | | | | |
| 52767 | CUSTODIAN OFFICE | | | | | | | | | | | | | | | X | | | | | | | | |

| Relinquished by: | Accepted by: | Date: | Time: |
|---|---|---|---|
| | | 10/14/16 | 1245 |
| | | 10/14/16 | 300 |
| | | 10/14/16 | 17:02 |

**Comments, Special Requirements or Regulations:**

Putnam Valley School District
173 Oscawana Lake Road
Putnam Valley, NY 10579

**Turnaround:**
☐ 1 Day*
☐ 2 Days*
☐ 3 Days* Day*
☐ 5 Days
☐ 10 Days
☐ Other
* SURCHARGE APPLIES

**NJ**
☐ Res. Criteria
☐ Non-Res. Criteria
☐ Impact to GW Soil Cleanup Criteria
☐ GW Criteria

**NY**
☐ TAGM 4046 GW
☐ TAGM 4046 SOIL
☐ NY375 Unrestricted Soil
☐ NY375 Residential Soil
☐ NY375 Restricted Non-Residential Soil

**Data Format**
☐ Phoenix Std Report
☐ Excel
☐ PDF
☐ GIS/Key
☐ EQuIS
☐ NJ Hazsite EDD
☐ NY EZ EDD (ASP)
☐ Other

**Data Package**
☐ NJ Reduced Deliv. *
☐ NY Enhanced (ASP B) *
☐ Other

**State where samples were collected:** NY

# NY/NJ CHAIN OF CUSTODY RECORD

Temp 20 ON IC  Pg 5 of 9

**PHOENIX** *Environmental Laboratories, Inc.*

587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06040
Email: info@phoenixlabs.com  Fax (860) 645-0823
**Client Services (860) 645-8726**

**Data Delivery:**
☐ Fax #:
☒ Email: joe@beeandjayplumbing.com

| | | | | | |
|---|---|---|---|---|---|
| Customer: | Bee & Jay Water Systems | Project: | PUT VAL MIDDLE SCHOOL | Project P.O: | |
| Address: | P.O. Box 78, Route 6 | Report to: | Joseph Scollan | Phone #: | 845-628-3924 |
| | Mahopac, NY 10541 | Invoice to: | | Fax #: | 845-628-4062 |

**Client Sample - Information - Identification**

Sampler's Signature: Date: 10/14/16

**Matrix Code:**
**DW**=drinking water **WW**=wastewater **S**=soil/solid **O**=oil
**GW**=groundwater **SL**=sludge **A**=air **X**=other

Analysis Request

| Phoenix Sample # | Customer Sample Identification | Sample Matrix | Date Sampled | Time Sampled | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD |
|---|---|---|---|---|---|---|---|---|---|---|---|
| S2768 | FACULTY BATH WEST | DW | 10/14 | 1ST DRAW | X | | | | | | |
| S2769 | BOYS ROOM 204 M | | | | | X | | | | | |
| S2770 | HANDICAP BATH L | | | | | | X | | | | |
| S2771 | NURSES BACKROOM | | | | | | | X | | | |
| S2772 | WATER FOUNTAIN BY MAIN OFFICES | | | | | | | | X | | |
| S2773 | NURSES BATHROOM | | | | | | | | | X | |
| S2774 | LIBRARY | | | | | | | | | | X |

Soil VOA [ ] Methanol [ ] S. Bisulfate [ ] H2O
GL Soil container ( ) oz
GL Soil container ( ) oz
40 ml VOA Vial [ ] As is [ ] HCl
GL Amber 1000ml [ ] As is [ ] H2SO4
PL As is [ ] 250ml [ ] 500ml [ ] 1000ml
PL H2SO4 [ ] 250ml [ ] 500ml
PL HNO3 250ml
PL NaOH 250ml
Bacteria Bottle

| Relinquished by: | Accepted by: | Date: | Time: |
|---|---|---|---|
| | | 10/14/16 | 1545 |
| | | 10/14/16 | 3CR |
| | | 10/14/16 | 17:00 |

**Comments, Special Requirements or Regulations:**

Putnam Valley School District
173 Oscawana Lake Road
Putnam Valley, NY 10579

**Turnaround:**
☐ 1 Day*
☐ 2 Days*
☐ 3 Days* Day*
☐ 5 Days
☐ 10 Days
☐ Other
* SURCHARGE APPLIES

**NJ**
☐ Res. Criteria
☐ Non-Res. Criteria
☐ Impact to GW Soil Cleanup Criteria
☐ GW Criteria

**NY**
☐ TAGM 4046 GW
☐ TAGM 4046 SOIL
☐ NY375 Unrestricted Soil
☐ NY375 Residential Soil
☐ NY375 Restricted Non-Residential Soil

**Data Format**
☐ Phoenix Std Report
☐ Excel
☐ PDF
☐ GIS/Key
☐ EQuIS
☐ NJ Hazsite EDD
☐ NY EZ EDD (ASP)
☐ Other

**Data Package**
☐ NJ Reduced Deliv. *
☐ NY Enhanced (ASP B) *
☐ Other

**State where samples were collected:** NY

# PHOENIX Environmental Laboratories, Inc.

## NY/NJ CHAIN OF CUSTODY RECORD

Temp 22 onice Pg 6 of 9

587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06040
Email: info@phoenixlabs.com Fax (860) 645-0823
**Client Services (860) 645-8726**

**Data Delivery:**
☐ Fax #:
☒ Email: joe@beeandjayplumbing.com

Customer: Bee & Jay Water Systems
Address: P.O. Box 78, Route 6
Mahopac, NY 10541

Project: PUTNAM HIGH SCHOOL
Report to: Joseph Scollan
Invoice to:

Project P.O:
Phone #: 845-628-3924
Fax #: 845-628-4062

**Client Sample - Information - Identification**

Sampler's Signature: [signature] Date: 10/14/16

**Matrix Code:**
DW=drinking water WW=wastewater S=soil/solid O=oil
GW=groundwater SL=sludge A=air X=other

Analysis Request

| Phoenix Sample # | Customer Sample Identification | Sample Matrix | Date Sampled | Time Sampled | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | Soil VOA [ ] Methanol [ ] S. Bisulfate [ ] H2O | GL Soil container ( ) oz | GL Soil container ( ) oz | 40 ml VOA Vial [ ] As is [ ] HCl | GL Amber 1000ml [ ] As is [ ] H2SO4 | PL As is [ ] 250ml [ ] 500ml [ ] 1000ml | PL H2SO4 [ ] 250ml [ ] 500ml | PL HNO3 250ml | PL NaOH 250ml | Bacteria Bottle |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 52775 | 1ST FLOOR FISH BOWL WATER FOUNTAIN L | DW | 10/14 | | X | X | X | X | X | X | X | X | X | X | | | | | | | | | | |
| 52776 | BOYS ROOM GYM L * | | | | | | | | | | | | | | | | | | | | | | | |
| 52777 | 1ST FLOOR BOYS ROOM FISH BOWL L | | | | | | | | | | | | | | | | | | | | | | | |
| 52778 | 1ST FLOOR GIRLS FISH BOWL R | | | | | | | | | | | | | | | | | | | | | | | |
| 52779 | 1ST FLOOR FISH BOWL SLOP SINK | | | | | | | | | | | | | | | | | | | | | | | |
| 52780 | ROOM 109 L | | | 1ST | | | | | | | | | | | | | | | | | | | | |
| 52781 | ROOM 109 R | | | R.R. DW | | | | | | | | | | | | | | | | | | | | |
| 52782 | BOYS ROOM GYM R | | | | | | | | | | | | | | | | | | | | | | | |
| 52783 | 1ST FLOOR FISH BOWL FACULTY GIRLS | | | | | | | | | | | | | | | | | | | | | | | |
| 52784 | 1ST FLOOR FISH BOWL BOYS | | | | | | | | | | | | | | | | | | | | | | | |
| 52785 | 1ST FLOOR FISH BOWL GIRLS L | | | | | | | | | | | | | | | | | | | | | | | |
| 52786 | BOYS LOCKER ROOM L | | | | | | | | | | | | | | | | | | | | | | | |

| Relinquished by: | Accepted by: | Date: | Time: |
|---|---|---|---|
| [signature] | [signature] | 10/14/16 | 12:41 |
| [signature] | [signature] | 10/14/16 | 3pm |
| [signature] | [signature] | 10/14/16 | 17:03 |

**Comments, Special Requirements or Regulations:**

* Not Rcvd @

Putnam Valley School District
Attn: Paul Lee
173 Oscawana Lake Road
Putnam Valley, NY 10579

**Turnaround:**
☐ 1 Day*
☐ 2 Days*
☐ 3 Days* Day*
☐ 5 Days
☐ 10 Days
☐ Other
* SURCHARGE APPLIES

**NJ**
☐ Res. Criteria
☐ Non-Res. Criteria
☐ Impact to GW Soil Cleanup Criteria
☐ GW Criteria

**NY**
☐ TAGM 4046 GW
☐ TAGM 4046 SOIL
☐ NY375 Unrestricted Soil
☐ NY375 Residential Soil
☐ NY375 Restricted Non-Residential Soil

**Data Format**
☐ Phoenix Std Report
☐ Excel
☐ PDF
☐ GIS/Key
☐ EQuIS
☐ NJ Hazsite EDD
☐ NY EZ EDD (ASP)
☐ Other

**Data Package**
☐ NJ Reduced Deliv. *
☐ NY Enhanced (ASP B) *
☐ Other

**State where samples were collected:** NY

# PHOENIX Environmental Laboratories, Inc.

## NY/NJ CHAIN OF CUSTODY RECORD

Temp 22 ON ICE Pg 1 of 1

587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06040
Email: info@phoenixlabs.com Fax (860) 645-0823
**Client Services (860) 645-8726**

**Data Delivery:**
☐ Fax #:
☒ Email: joe@beeandjayplumbing.com

Customer: Bee & Jay Water Systems
Address: P.O. Box 78, Route 6
Mahopac, NY 10541

Project: PUTNAM VALLEY HIGH SCHOOL
Report to: Joseph Scollan
Invoice to:

Project P.O:
Phone #: 845-628-3924
Fax #: 845-628-4062

Sampler's Signature: [signature] Date: 10/14/16

**Client Sample - Information - Identification**

**Matrix Code:**
DW=drinking water WW=wastewater S=soil/solid O=oil
GW=groundwater SL=sludge A=air X=other

Analysis Request

| Phoenix Sample # | Customer Sample Identification | Sample Matrix | Date Sampled | Time Sampled | LEAD |
|---|---|---|---|---|---|
| 52787 | 118 TEACHER Room | DW | 10/14 | 1ST DRAW | X |
| 52788 | 122 R | | | | X |
| 52789 | GIRLS Room GYM R | | | | X |
| * 52790 | GIRLS ROOM GYM L | | | | X |
| 52791 | 1ST FLOOR FISHBOWL FACULTY MENS | | | | X |
| 52792 | 1ST FLOOR FISHBOWL GIRLS M | | | | X |
| 52793 | TEAM LOCKER Room | | | | X |
| 52794 | BOYS LOCKER Room R | | | | X |
| 52795 | 1ST FLOOR FISHBOWL FOUNTAIN R | | | | X |
| 52796 | ICE MACHINE | | | | X |
| 52797 | 113 R | | | | X |
| 52798 | DARK Room | | | | X |

| Relinquished by: | Accepted by: | Date: | Time: |
|---|---|---|---|
| [signature] | [signature] | 10/14/16 | 12:45 |
| [signature] | [signature] | 10/14/16 | 3pm |
| [signature] | [signature] | 10/14/16 | 17:00 |

**Comments, Special Requirements or Regulations:**
*Rcvd 2 samples labeled girls Room Gym L (CP)

Putnam Valley School District
Attn: Paul Lee
173 Oscawana Lake Road
Putnam Valley, NY 10579

**Turnaround:**
☐ 1 Day*
☐ 2 Days*
☐ 3 Days* Day*
☐ 5 Days
☐ 10 Days
☐ Other
* SURCHARGE APPLIES

**NJ**
☐ Res. Criteria
☐ Non-Res. Criteria
☐ Impact to GW Soil Cleanup Criteria
☐ GW Criteria

**NY**
☐ TAGM 4046 GW
☐ TAGM 4046 SOIL
☐ NY375 Unrestricted Soil
☐ NY375 Residential Soil
☐ NY375 Restricted Non-Residential Soil

**Data Format**
☐ Phoenix Std Report
☐ Excel
☐ PDF
☐ GIS/Key
☐ EQuIS
☐ NJ Hazsite EDD
☐ NY EZ EDD (ASP)
☐ Other

**Data Package**
☐ NJ Reduced Deliv. *
☐ NY Enhanced (ASP B) *
☐ Other

**State where samples were collected:** NY

# NY/NJ CHAIN OF CUSTODY RECORD

Temp 22°NC Pg 8 OF 9

**PHOENIX** *Environmental Laboratories, Inc.*

587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06040
Email: info@phoenixlabs.com Fax (860) 645-0823
**Client Services (860) 645-8726**

**Data Delivery:**
☐ Fax #:
☒ Email: joe@beeandjayplumbing.com

Customer: Bee & Jay Water Systems
Address: P.O. Box 78, Route 6
Mahopac, NY 10541

Project: PUT VAL HIGH SCHOOL
Report to: Joseph Scollan
Invoice to:

Project P.O:
Phone #: 845-628-3924
Fax #: 845-628-4062

**Client Sample - Information - Identification**

Sampler's Signature: Date: 10/14/16

**Matrix Code:**
DW=drinking water WW=wastewater S=soil/solid O=oil
GW=groundwater SL=sludge A=air X=other

Analysis Request

| Phoenix Sample # | Customer Sample Identification | Sample Matrix | Date Sampled | Time Sampled | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD |
|---|---|---|---|---|---|---|---|---|---|---|
| 52799 | SLOP SINK BY GYM | DW | 10/14 | UP DRAIN | X | | | | | |
| 52800 | GIRLS LOCKER ROOM R | | | | | X | | | | |
| 52801 | 122 L | | | | | | b | | | |
| 52802 | 1ST FLOOR FISHBOWL BOYS ROOM M | | | | | | | b | | |
| 52803 | 113 L | | | | | | | | X | |
| 52804 | GIRLS LOCKER ROOM L | | | | | | | | | b |

Soil VOA [ ] Methanol [ ] S. Bisulfate [ ] H2O
GL Soil container ( ) oz
GL Soil container ( ) oz
40 ml VOA Vial [ ] As is [ ] HCl
GL Amber 1000ml [ ] As is [ ] H2SO4
PL As is [ ] 250ml [ ] 500ml [ ] 1000ml
PL H2SO4 [ ] 250ml [ ] 500ml
PL HNO3 250ml
PL NaOH 250ml
Bacteria Bottle

| Relinquished by: | Accepted by: | Date: | Time: |
|---|---|---|---|
| | | 10/14/16 | 12:47 |
| | | 10/14/16 | 3 pm |
| | | 10/14/16 | 17:02 |

**Comments, Special Requirements or Regulations:**

Putnam Valley School District
Attn: Paul Lee
173 Oscawana Lake Road
Putnam Valley, NY 10579

**Turnaround:**
☐ 1 Day*
☐ 2 Days*
☐ 3 Days* Day*
☐ 5 Days
☐ 10 Days
☐ Other
* SURCHARGE APPLIES

**NJ**
☐ Res. Criteria
☐ Non-Res. Criteria
☐ Impact to GW Soil Cleanup Criteria
☐ GW Criteria

**NY**
☐ TAGM 4046 GW
☐ TAGM 4046 SOIL
☐ NY375 Unrestricted Soil
☐ NY375 Residential Soil
☐ NY375 Restricted Non-Residential Soil

**Data Format**
☐ Phoenix Std Report
☐ Excel
☐ PDF
☐ GIS/Key
☐ EQuIS
☐ NJ Hazsite EDD
☐ NY EZ EDD (ASP)
☐ Other

**Data Package**
☐ NJ Reduced Deliv. *
☐ NY Enhanced (ASP B) *
☐ Other

**State where samples were collected:** NY

# NY/NJ CHAIN OF CUSTODY RECORD

Temp 22 on ice Pg 9 of 9

**PHOENIX** *Environmental Laboratories, Inc.*

587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06040
Email: info@phoenixlabs.com Fax (860) 645-0823
**Client Services (860) 645-8726**

**Data Delivery:**
☐ Fax #:
☒ Email: joe@beeandjayplumbing.com

Customer: Bee & Jay Water Systems
Address: P.O. Box 78, Route 6
Mahopac, NY 10541

Project: PUT VAL. CONCESSION STAND
Report to: Joseph Scollan
Invoice to:

Project P.O:
Phone #: 845-628-3924
Fax #: 845-628-4062

**Client Sample - Information - Identification**

Sampler's Signature: Henry Weber Date: 10/14/16

**Matrix Code:**
**DW**=drinking water **WW**=wastewater **S**=soil/solid **O**=oil
**GW**=groundwater **SL**=sludge **A**=air **X**=other

Analysis Request

| Phoenix Sample # | Customer Sample Identification | Sample Matrix | Date Sampled | Time Sampled | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | | | Soil VOA [ ] Methanol [ ] S. Bisulfate [ ] H2O | GL Soil container ( ) oz | GL Soil container ( ) cc | 40 ml VOA Vial [ ] As is [ ] HCl | GL Amber 1000ml [ ] As is [ ] H2SO4 | PL As is [ ] 250ml [ ] 500ml [ ] 1000ml | PL H2SO4 [ ] 250ml [ ] 500ml [ ] 1000ml | PL HNO3 250ml | PL NaOH 250ml | Bacteria Bottle |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| S2805 | KITCHEN SINK | DW | 10/14 | 1130 | X | | | | | | | | | | | | | | | | | | |
| S2806 | WATER FOUNTAIN L | | | | | X | | | | | | | | | | | | | | | | | |
| S2807 | LADIES ROOM | | | | | | X | | | | | | | | | | | | | | | | |
| S2808 | ICE MACHINE | | | | | | | X | | | | | | | | | | | | | | | |
| S2809 | SPIGOT BY FOUNTAIN | | | | | | | | X | | | | | | | | | | | | | | |
| S2810 | WATER FOUNTAIN R | | | DRAW | | | | | | X | | | | | | | | | | | | | |
| S2811 | MENS ROOM | | | | | | | | | | X | | | | | | | | | | | | |

| Relinquished by: | Accepted by: | Date: | Time: |
|---|---|---|---|
| | | 10/14/16 | 1241 |
| | | 10/14/16 | 3pm |
| | | 10/14/16 | 17:02 |

**Comments, Special Requirements or Regulations:**

Putnam Valley School District
Attn: Paul Lee
173 Oscawana Lake Road
Putnam Valley, NY 10579

**Turnaround:**
☐ 1 Day*
☐ 2 Days*
☐ 3 Days* Day*
☐ 5 Days
☐ 10 Days
☐ Other
* SURCHARGE APPLIES

**NJ**
☐ Res. Criteria
☐ Non-Res. Criteria
☐ Impact to GW Soil Cleanup Criteria
☐ GW Criteria

**NY**
☐ TAGM 4046 GW
☐ TAGM 4046 SOIL
☐ NY375 Unrestricted Soil
☐ NY375 Residential Soil
☐ NY375 Restricted Non-Residential Soil

**Data Format**
☐ Phoenix Std Report
☐ Excel
☐ PDF
☐ GIS/Key
☐ EQuIS
☐ NJ Hazsite EDD
☐ NY EZ EDD (ASP)
☐ Other

**Data Package**
☐ NJ Reduced Deliv. *
☐ NY Enhanced (ASP B) *
☐ Other

**State where samples were collected:** NY

# PHOENIX Environmental Laboratories, Inc.

## NY/NJ CHAIN OF CUSTODY RECORD

Temp 20 onice Pg 6 of 9

587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06040
Email: info@phoenixlabs.com Fax (860) 645-0823
**Client Services (860) 645-8726**

**Data Delivery:**
☐ Fax #:
☒ Email: joe@beeandjayplumbing.com

Customer: Bee & Jay Water Systems
Address: P.O. Box 78, Route 6
Mahopac, NY 10541

Project: PUTNAM HIGH SCHOOL
Report to: Joseph Scollan
Invoice to:

Project P.O:
Phone #: 845-628-3924
Fax #: 845-628-4062

GBV 52720

Sampler's Signature: [signature] Date: 10/14/16

**Client Sample - Information - Identification**

**Matrix Code:**
DW=drinking water WW=wastewater S=soil/solid O=oil
GW=groundwater SL=sludge A=air X=other

Analysis Request

| Phoenix Sample # | Customer Sample Identification | Sample Matrix | Date Sampled | Time Sampled | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | Soil VOA [ ] Methanol [ ] S. Bisulfate [ ] H2O | GL Soil container ( ) oz | GL Soil container ( ) oz | 40 ml VOA Vial [ ] As is [ ] HCl | GL Amber 1000ml [ ] As is [ ] H2SO4 | PL As is [ ] 250ml [ ] 500ml [ ] 1000ml | PL H2SO4 [ ] 250ml [ ] 500ml | PL HNO3 250ml | PL NaOH 250ml | Bacteria Bottle |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 52775 | 1ST FLOOR FISH BOWL WATER FOUNTAINS L | DW | 10/14 | | X | | | | | | | | | | | | | | | | | | | |
| 52776 | BOYS ROOM GYM L | | | | | X | | | | | | | | | | | | | | | | | | |
| 52777 | 1ST FLOOR BOYS ROOM FISH BOWL L | | | | | | X | | | | | | | | | | | | | | | | | |
| 52778 | 1ST FLOOR GIRLS FISH BOWL R | | | | | | | X | | | | | | | | | | | | | | | | |
| 52779 | 1ST FLOOR FISH BOWL SLOP SINK | | | | | | | | X | | | | | | | | | | | | | | | |
| 52780 | ROOM 109 L | | | 1ST | | | | | | X | | | | | | | | | | | | | | |
| 52781 | ROOM 109 R | | | R RM | | | | | | | X | | | | | | | | | | | | | |
| 52782 | BOYS ROOM GYM R | | | | | | | | | | | X | | | | | | | | | | | | |
| 52783 | 1ST FLOOR FISH BOWL FACULTY GIRLS | | | | | | | | | | | | X | | | | | | | | | | | |
| 52784 | 1ST FLOOR FISH BOWL BOYS | | | | | | | | | | | | | X | | | | | | | | | | |
| 52785 | 1ST FLOOR FISH BOWL GIRLS L | | | | | | | | | | | | | | X | | | | | | | | | |
| 52786 | BOYS LOCKER ROOM L | | | | | | | | | | | | | | | | | | | | | | | |

| Relinquished by: | Accepted by: | Date: | Time: |
|---|---|---|---|
| [signature] | [signature] | 10/14/16 | 12:41 |
| [signature] | [signature] | 10/14/16 | 3pm |
| [signature] | [signature] | 10/14/16 | 19:00 |

**Comments, Special Requirements or Regulations:**

*Not Rcvd @

* cancel per Kim @ Bee & Jay - will resample (OT)

Putnam Valley School District
Attn: Paul Lee
173 Oscawana Lake Road
Putnam Valley, NY 10579

**Turnaround:**
☐ 1 Day*
☐ 2 Days*
☐ 3 Days* Day*
☐ 5 Days
☐ 10 Days
☐ Other
* SURCHARGE APPLIES

**NJ**
☐ Res. Criteria
☐ Non-Res. Criteria
☐ Impact to GW Soil Cleanup Criteria
☐ GW Criteria

**NY**
☐ TAGM 4046 GW
☐ TAGM 4046 SOIL
☐ NY375 Unrestricted Soil
☐ NY375 Residential Soil
☐ NY375 Restricted Non-Residential Soil

**Data Format**
☐ Phoenix Std Report
☐ Excel
☐ PDF
☐ GIS/Key
☐ EQuIS
☐ NJ Hazsite EDD
☐ NY EZ EDD (ASP)
☐ Other

**Data Package**
☐ NJ Reduced Deliv. *
☐ NY Enhanced (ASP B) *
☐ Other

**State where samples were collected:** NY

# NY/NJ CHAIN OF CUSTODY RECORD

Temp 2.0°C Pg 1 of 1

**PHOENIX** Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06040
Email: info@phoenixlabs.com Fax (860) 645-0823
**Client Services (860) 645-8726**

**Data Delivery:**
☐ Fax #:
☒ Email: joe@beeandjayplumbing.com

Customer: Bee & Jay Water Systems
Address: P.O. Box 78, Route 6
Mahopac, NY 10541

Project: PUTNAM HIGH SCHOOL
Report to: Joseph Scollan
Invoice to:

Project P.O:
Phone #: 845-628-3924
Fax #: 845-628-4062

GBU 52720

Sampler's Signature: Joseph Scollan Date: 10/14/16

**Client Sample - Information - Identification**

**Matrix Code:**
DW=drinking water WW=wastewater S=soil/solid O=oil
GW=groundwater SL=sludge A=air X=other

Analysis Request

| Phoenix Sample # | Customer Sample Identification | Sample Matrix | Date Sampled | Time Sampled | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | LEAD | Soil VOA [ ] Methanol [ ] S. Bisulfate [ ] H2O | GL Soil container ( ) oz | GL Soil container ( ) oz | 40 ml VOA Vial [ ] As is [ ] HCl | GL Amber 1000ml [ ] As is [ ] H2SO4 | PL As is [ ] 250ml [ ] 500ml [ ] 1000ml | PL H2SO4 [ ] 250ml [ ] 500ml | PL HNO3 250ml | PL NaOH 250ml | Bacteria Bottle |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 52787 | 118 TEACHER Room | | | | X | | | | | | | | | | | | | | | | | | | | |
| 52788 | 122 R | | | | | X | | | | | | | | | | | | | | | | | | | |
| 52789 | GIRLS Room GYM R | | | | | | X | | | | | | | | | | | | | | | | | | |
| *52790 | GIRLS Room GYM L | DW | 10/14 | 1ST DRAW | | | | X | | | | | | | | | | | | | | | | | |
| 52791 | 1ST FLOOR FISHBOWL FACULTY MEN'S | | | | | | | | X | | | | | | | | | | | | | | | | |
| 52792 | 1ST FLOOR FISHBOWL GIRLS M | | | | | | | | | X | | | | | | | | | | | | | | | |
| 52793 | TEAM LOCKER Room | | | | | | | | | | X | | | | | | | | | | | | | | |
| 52794 | BOYS LOCKER Room R | | | | | | | | | | | X | | | | | | | | | | | | | |
| 52795 | 1ST FLOOR FISHBOWL FOUNTAIN R | | | | | | | | | | | | X | | | | | | | | | | | | |
| 52796 | ICE MACHINE | | | | | | | | | | | | | X | | | | | | | | | | | |
| 52797 | 113 R | | | | | | | | | | | | | | X | | | | | | | | | | |
| 52798 | DARK Room | | | | | | | | | | | | | | | X | | | | | | | | | |

| Relinquished by: | Accepted by: | Date: | Time: |
|---|---|---|---|
| | | 10/14/16 | 12:45 |
| | | 10/14/16 | 3pm |
| | | 10/14/16 | 17:00 |

**Comments, Special Requirements or Regulations:**
*Rcvd 2 samples labeled girls Room Gym L (CP)

Putnam Valley School District
Attn: Paul Lee
173 Oscawana Lake Road
Putnam Valley, NY 10579

*cancel per Kim @ Bee & Jay
-will resample (CP)

**Turnaround:**
☐ 1 Day*
☐ 2 Days*
☐ 3 Days* Day*
☐ 5 Days
☐ 10 Days
☐ Other
* SURCHARGE APPLIES

**NJ**
☐ Res. Criteria
☐ Non-Res. Criteria
☐ Impact to GW Soil Cleanup Criteria
☐ GW Criteria

**NY**
☐ TAGM 4046 GW
☐ TAGM 4046 SOIL
☐ NY375 Unrestricted Soil
☐ NY375 Residential Soil
☐ NY375 Restricted Non-Residential Soil

**Data Format**
☐ Phoenix Std Report
☐ Excel
☐ PDF
☐ GIS/Key
☐ EQuIS
☐ NJ Hazsite EDD
☐ NY EZ EDD (ASP)
☐ Other

**Data Package**
☐ NJ Reduced Deliv. *
☐ NY Enhanced (ASP B) *
☐ Other

**State where samples were collected:** NY